

PLANNED MAINTENANCE INSPECTION FOR GENERATORS

<input type="checkbox"/>	623 Huffman Lift Station 33 S. Huffman	<input type="checkbox"/>	631 Southeast Waterworks 1699 Ranchview	<input type="checkbox"/>	639 South Waterworks 1301 Clyde Dr.
<input type="checkbox"/>	624 Paddock Lift Station 1900 Saddle Farm Drive	<input type="checkbox"/>	632 Riverwoods Lift Station 2241 Riverwoods Dr.	<input type="checkbox"/>	640 West Highlands Lift Station 322 W. Gartner
<input type="checkbox"/>	625 Monarch Landing Lift Station 2403 Corporate Lane	<input type="checkbox"/>	633 West Waterworks 1006 Whispering Hills	<input type="checkbox"/>	641 Trillium Lift Station 2426 Trillium
<input type="checkbox"/>	626 Northwest Waterworks 1608 W. Diehl	<input type="checkbox"/>	634 Cinnamon Creek 1301 Ranchview Drive	<input type="checkbox"/>	642 Bonnema Woods Lift Station 2315 Bill Ct.
<input type="checkbox"/>	627 Summerfield Lift Station 1939 Skylane Dr.	<input type="checkbox"/>	635 Country Lakes Lift Station 2079 N. Aurora Rd.	<input type="checkbox"/>	643 South Pointe Lift Station 2199 Spartina Dr.
<input type="checkbox"/>	628 Century Hills Lift Station 25W222 Maple Ave.	<input type="checkbox"/>	636 Hobson Oaks Lift Station 1229 Hobson Oaks Dr.	<input type="checkbox"/>	657 Barclay Manor 300 N. Charles
<input type="checkbox"/>	629 S.O.C. Pumping Station 1800 S. Washington	<input type="checkbox"/>	637 Royce Road Lift Station 301 Royce Road	<input type="checkbox"/>	658 Northwest Lift Station Ogden & River Rd.
<input type="checkbox"/>	630 Northeast Waterworks 1593 N. Naper Blvd.	<input type="checkbox"/>	638 River Mist Lift Station 2489 W. Branch Ct.	<input type="checkbox"/>	659 Southwest Lift Station 111th & Book
<input type="checkbox"/>		<input type="checkbox"/>		<input type="checkbox"/>	North Operations Center 1200 W. Ogden

ENGINE

☐ Belts

OIL SYSTEM

☐ Check entire unit for oil leaks  
☐ Check engine oil level

COOLING SYSTEM

☐ Check engine radiator coolant level  
☐ Check for leaks & hose condition  
☐ Check block heater & water temp.

EXHAUST SYSTEM

☐ Inspect for leaks, drain condensation trap if applicable

KEY:

M	Monthly
B	Biweekly
W	Weekly
P	Potential Problem
X	Urgent Problem
O	O.K.
A	Adjust
R	Repair or Replace

FUEL SYSTEM

☐ Check flexible connections & lines  
☐ Check day tank float level  
☐ Fuel filter for leaks  
☐ Check & record fuel supply \_\_\_\_\_

BATTERY

☐ Check battery starting system  
☐ Battery charger-record readings  
AMPS \_\_\_\_\_ VOLTS \_\_\_\_\_  
☐ Check solution level  
☐ Check connections and clean  
☐ Note overall condition of system  
☐ Record current Hour Meter \_\_\_\_\_

MISCELLANEOUS

☐ Check engine mounts  
☐ Check exhaust mounts & smoke  
☐ Check oil pan  
☐ Check abnormal sounds  
☐ Check vibrations

AUTOMATIC SWITCH

☐ Inspect instruments & gauges  
☐ Check battery charger  
☐ Start and stop unit from switch, 15 min.

OPERATING CHECK

☐ Run generator and check for:  
☐ Overspeed, low oil pressure,  
☐ high water temperature

FLEET SERVICES DIVISION

PHONE: 420-6086 FAX: 420-4100

Note: Please send a copy of this inspection to Fleet Services at the end of each month.

TECHNICIAN: \_\_\_\_\_

DATE: \_\_\_\_\_